



DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC

INSPECTION DATE: 10/19/2015

WEATHER: Clear skies, 50's

INSPECTED BY: Brian Hall

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	0832 hours. No changes
Erosion	N	N	from previous inspection
Low Point, B dike*			
Flow	N	N	0836 hours. No changes
Erosion	N	N	From previous inspection
Outfall water surface El. (top of stoplogs to water)			0835 hours No water flowing into weir. Discharge pipe sealed. Pumps are not running

* See figure below.

Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.): No standing water where there had been some at the base of the slope between A and B.

